

Introduction


All integrity test procedures outlined below should be followed when performing integrity testing of membrane filters only. Use of these procedures on other types of filters such as polypropylene or glass fiber cartridges will not give consistent or accurate results.

Cartridge Wetting

Prior to any integrity test procedure, the cartridge membrane must be thoroughly wetted. If the membrane is not fully wetted, hydrophobic or un-wetted spots will give a false failure for any of the tests outlined below. Refer to Figure 1 for the Wetting and Integrity Test Set-up.

1. Cut off the polyethylene bag at the O-ring end of the cartridge. Be careful not to damage the O-rings.
2. Remove the polyethylene sleeve from the cartridge. The cartridge must be handled consistent with its intended use. For example, some applications may require special procedures such as, wearing of gloves, pre-sterilization of the cartridge, etc.
3. Place the cartridge into the housing, closing the housing securely. With the downstream valves (V8 and V9) and vent valve (V7) open, slowly open the upstream valve (V1) to allow filtered water or the selected test fluid into the housing. Once fluid is observed coming out the vent valve (V7) with no bubbles present in the fluid, close the vent valve and allow the fluid to pass through the housing at 2 liters per minute.
4. Allow fluid flow for a total of 10 minutes
5. Start closing the downstream valve (V9 and V8) to reduce water flow and increase inlet pressure. Bring the inlet pressure up to 15-20 psi by reducing the flow through the downstream valve.

Figure 1 – Wetting & Integrity Test Setup



NOTE: If the cartridge integrity test will be conducted when the filter is installed in the process system, but the filter requires wetting with a fluid different from the normal process fluid to be filtered, the user may wet the filter in a separate housing using the same procedure as described above, then remove the wetted filter and install it in the process system. If the filter application is bacteria removal, then the filter and system should be disinfected or sterilized after the integrity test is complete and before use.

Cartridge Integrity Test - Bubble Point

Refer to Figure 1, which represents a typical layout for an integrity test system.

1. If appropriate, remove the filter cartridge from the housing used for wetting the cartridge, drain all excess wetting solution from cartridge and install it into the housing used for the integrity testing.
2. Starting with all valves in the closed position, open the downstream valves (V8 and V9).
3. Connect the pressure regulated air supply line to valve V4. Open the drain valve (V6) and Vent valve (V7) and purge any upstream fluid at 2 psig. Close the drain and vent valves (V6 and V7) when flow becomes mostly air.
4. Close valve V9 and open valve V10.
5. Increase the air pressure in increments of 2 psig holding for 5 seconds at each step until significantly higher mass flow is measured. Record the pressure when the mass flow increases significantly. This is the bubble point.
6. A bubble point value lower than that specified indicates that the system is not integral.

Procedure Note: Due to the subjectivity in the interpretation of this test, a 10 inch cartridge bubble point is arbitrarily defined as air flow of 50 cc per minute or higher, after the pressure has stabilized.

NOTE: If the cartridge appears to fail the initial bubble point test, repeat the Cartridge Wetting procedure and increase the rinse time to twice the initial amount to assure that the media has been properly wetted. Then retest. If necessary, check the cartridge seal in the housing.

Cartridge Integrity Test - Diffusive Flow

Refer to Figure 1, which represents a typical layout for an integrity test system.

1. Install and rinse cartridges as per Cartridge Wetting instructions.
2. Starting with all valves in the closed position, open valves V8 and V9. Downstream must be open to ambient pressure.
3. Connect a pressure regulated air (gas) supply and open valve V4. (If possible, pressure should be regulated to the desired test pressure.)
4. Open the drain valve (V6) and vent valve (V7) and purge upstream test fluid at 2 psig. Close valves V6 and V7 when flow becomes mostly air.
5. Slowly increase the air pressure, as measured on the upstream pressure gauge (G1) or mass flow meter to the amount on the test specification supplied by Critical Process Filtration (usually 80% of the specified bubble point).
6. Allow the system to equilibrate. If the regulated air supply is not set at the test pressure, maintain the specified pressure as measured at G4 by adjusting the flow of air using valve V4.
7. Record the air flow.
8. A diffusional flow (diffusion rate) reading higher than the specification indicates that the system is not integral.

NOTE: If the cartridge appears to fail the initial bubble point test, repeat the Cartridge Wetting procedure and increase the rinse time to twice the initial amount to assure that the media has been properly wetted. Then retest. If necessary, check the cartridge seal in the housing.



Cartridge Integrity Test - Pressure Hold

Refer to Figure 1, which represents a typical layout for an integrity test system.

The Pressure Hold Test, also known as Pressure Decay, is dependent on the specified diffusional flow and volume upstream of the filter and downstream of system valve V1. It can be calculated using the following equation:

$$\text{Pressure Hold Test Formula} = D (T) (Pa) = (DP) (Vh)$$

Where:

D = Diffusion rate cc/min

T = Time (minutes)

Pa = Atmospheric Pressure (14.7 psi)

DP = Pressure Drop (psi)

Vh = Upstream volume of apparatus (cc)

1. Install and rinse cartridges as per Cartridge Wetting instructions.
2. Starting with all valves in the closed position, open valves V8 and V9. Downstream must be open to ambient pressure.
3. Connect a pressure regulated air (gas) supply at V4 and open valves V4 and V5.
4. Open the drain valve (V6) and vent valve (V7) and purge upstream test fluid at 2 psig. Close valves V6 and V7 when flow becomes mostly air.
5. Slowly increase the air pressure, as measured on the upstream pressure gauge (G4) or mass flow meter, to the amount on the test specification supplied by Critical Process Filtration (usually 80% of the bubble point).
6. Close valve V5.
7. Read the pressure on gauge G4 at the end of the specified test time period.
8. The system is considered integral when the measured pressure drop is less than the calculated amount for the cartridge system for the test time.

Procedure Note: If the cartridge appears to fail the test, repeat the Cartridge Wetting procedure and increase the rinse time to twice the initial amount to insure that the membrane is properly wetted. Then retest. If necessary, check the cartridge seal in the housing.

NOTE: Filter Integrity should be tested in accordance with current good manufacturing practice for all critical applications before and after use. It is up to each individual customer to determine the best method and protocol required. The information provided is a recommendation and guide for integrity testing procedures, and the importance of proper cartridge wet out.

For help determining the test values or additional information, contact your representative or Critical Process Filtration.



Quality Standards

Our goal is to ensure our customers the greatest possible value for their filtration dollar. Our state of the art manufacturing facility and quality management system both meet ISO 9001:2008 standards. Each operation from assembly and test to cleaning, drying, and packaging is done in appropriately rated clean rooms. A sophisticated MRP system collects and processes real time data from manufacturing centers and inspection points. This allows variable and attribute data to be quickly and easily analyzed driving constant improvements in both quality and cost.

Total Performance

Critical Process Filtration, Inc. is a vertically integrated manufacturer of filtration products to industries in which filtration is considered a critical part of the manufacturing process. We supply a complete line of products and services to help you cost effectively satisfy all your filtration requirements from a single source.

Visit our [website](#) or [contact us](#) for more information.



Critical Process Filtration, Inc.
One Chestnut Street • Nashua, NH 03060
Tel: 603.880.4420 • Fax: 603.880.4536

criticalprocess.com • sales@criticalprocess.com

The information contained herein is subject to change without notice.
The Critical Process Filtration logo is a trademark of Critical Process Filtration, Inc.
© 1998-2016 Critical Process Filtration, Inc. • All Rights Reserved • ITWPROC0315 RevA